

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.


No. 66

Date : 28/5/19

It is certified that an inspection team headed by REENA CHEMIST  
PALWAL (Name of Officers  
with designation) from Public Health Engineering Department (Name of  
Department/Office) inspected the Drinking Water Sample of  
RAM Ji Lal Memorial Public School Mandnaka (Name & Address of  
the School) on 24/05/19 and found that the Ram Ji Lal Memorial  
Public School Mandnaka PALWAL (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of Six Months.

Signature with Seal :

  
Public Health Engineering  
Water Testing Laboratory  
PALWAL

Name

: REENA

Designation

: CHEMIST P.H.E.D  
PALWAL

To

RAM Ji Lal Memorial  
Public School Mandnaka  
PALWAL

(Name & Address of the Institution)



# OFFICE OF THE CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT WATER TESTING LABORATORY, PALWAL  
9MLD STP, JODHPUR ROAD, PALWAL, HARYANA - 121102  
E-mail:-chemist.palwal@phedharyana.gov.in, chemist.palwal@gmail.com



Test Report No.	→ PHL-374/2019	Issue Date: Memo No.:	→ 66 dt. 28/05/2019
Issued to	→ RAMJI LAL MEMORIAL PUBLIC SCHOOL, MANDNAKA Palwal	Location:	→ R/o Water at RAMJI LAL MEMORIAL PUBLIC SCHOOL, MANDNAKA PALWAL
Your Reference No.	→ RJ2019-20/101	Sample collected Date & Time:	→ 24/05/2019 at 11:00 A.M.
Reference Date	→ 24/05/2019	Sample received Date & Time:	→ 24/05/2019 at 11:30 A.M.
Sample Type	→ CHEMICAL TEST	GRN No.:	0047846324
Collection by	→ <i>Dharmender</i>	GRN Date:	24/05/2019
		Classification of Sample:	→ Private

### Test Result

Sr. No.	Tested Parameter	Results	Unit	Method	Acceptable	Permissible Limit (As per IS 10500:2012)
1	Total Dissolve Solids	112.3	Mg/l	IS:3025(Part16):1984 Reaffirmed-2006	500 Mg/l	2000 Mg/l
2	pH	7.11	---	IS:3025(Part-11):1983 Reaffirmed-2002	6.5-8.5	No Relaxation
3	Chlorides as (Cl)	35	Mg/l	IS:3025(Part32):1988 Reaffirmed-2003	250 Mg/l	1000 Mg/l
4	Hardness as CaCO <sub>3</sub>	60	Mg/l	IS:3025(Part21):2009 Reaffirmed-2003	300 Mg/l	600 Mg/l
5	Calcium as (Ca)	28	Mg/l	IS:3025(Part40):1991 Reaffirmed-2003	75 Mg/l	200 Mg/l
6	Magnesium (Mg)	0	Mg/l	IS:3025(Part46):1994 Reaffirmed-2003	30 Mg/l	100 Mg/l
7	Alkalinity	50	Mg/l	IS:3025 (Part23):1986 Reaffirmed -2003	200 Mg/l	600 Mg/l
8	Fluoride as (F)	0.46	Mg/l	4500-FD (APHA22 <sup>nd</sup> ,Edition2012)	1.0 Mg/l	1.5 Mg/l
9	Iron as (Fe)	0.11	Mg/l	3500-FeB (APHA22 <sup>nd</sup> ,Edition2012)	0.30 Mg/L	1.0 Mg/l
10	Nitrate as (No <sub>3</sub> )	4.9	Mg/l	4500-No <sub>3</sub> <sup>-</sup> (APHA22 <sup>nd</sup> ,Edition2012APHA	45 Mg/l	No Relaxation
11	Sulphate as (So <sub>4</sub> )	22	Mg/l	4500-So <sub>4</sub> <sup>2-</sup> E (APHA22 <sup>nd</sup> ,Edition2012)	200 Mg/l	400 Mg/l

Remarks: - Water Sample is Potable for above tested parameters.

### Specific contractual notes: -

- The results given above are related to the sample as received and tested in PHED Lab PALWAL.
- The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab PALWAL.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample lies with sender/collector of water sample.

*[Signature]*  
CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT  
WATER TESTING LABORATORY  
PALWAL